



*Pikes Peak  
Regional Building  
Department*

2880 International Circle Colorado Springs, CO 80910

Telephone 719-327-2880

Web address – [www.pprbd.org](http://www.pprbd.org)

## New labeling requirements for cord and plug connected portable generators:

When wiring transfer equipment for a cord and plug connection to a portable generator, a label stating the type of derived system that the transfer equipment is capable of being connected to shall now be placed next to the flanged inlet. If the transfer equipment is located outside, the label must be an engraved type label permanently fixed next to the flanged inlet. If the transfer equipment is located indoors, a Brothers (or similar) type printed label is acceptable. Not hand written.

The wording on the label shall be as follows depending on the system being used:

WARNING:

FOR CONNECTION OF A SEPARATELY DERIVED  
(BONDED NEUTRAL) SYSTEM ONLY

OR

WARNING:

FOR CONNECTION OF A NONSEPARATELY  
DERIVED (FLOATING NEUTRAL) SYSTEM ONLY

If the system is separately derived, the transfer equipment must switch the neutral.