

Pikes Peak Regional Building Department

2880 International Circle
Colorado Springs, Colorado 80910

ELECTRICAL COMMITTEE AGENDA

May 8, 2012

2:30 p.m.

MEMBERS PRESENT: Chairman Dennis Hathcock
Vice Chairman Waldo Pendleton
Mr. Mark Mahler
Mr. Daniel McCully
Mr. Ronald Holladay
Mr. Ashton Randall

MEMBERS ABSENTS: None

OTHERS PRESENT: Mr. Henry Yankowski, Regional Building Official
Mr. Dean Wemmer, Chief Electrical Inspector
Todd Welch, Regional Building Official
Ms. Linda Gardner, Executive Administrative Assistant

PROCEEDINGS:

The May 8, 2012 Electrical Committee Meeting was conducted by email.

VARIANCE REQUESTS

1. 12504 Mt. Belford Way, 3983 Reindeer Circle, 6230 Bearcat, 2275 Sierra Park, 6480 Tranters Creek, 17584 Cabin Hill, 5951 Adamants, 6330 Tranters Creek, 7694 Manistique, 7353 Running Deer, 7395 Willowdale, 4958 Haiti, 7396 Willowdale, 10823 Hidden Ridge, 7438 Willowdale, 6478 Passing Sky, 9984 Tomcat, 3854 Papuan Drive, 12399 Handles Peak, 7621 Dellwood - Melvin Denke, Fountain Valley Electrical, requests a variance to Section 210.12, 2008 National Electrical Code, to install regular 15 amp. breakers in place of arc fault breakers.

A motion was made by Dennis Hathcock to recommend to the Board of Review **APPROVAL** of the variance request, seconded by Ron Holladay; the motion carried unanimously.

Respectfully submitted,

Henry W. Yankowski
Regional Building Official
HWY/llg