

Pikes Peak Regional Building Department

2880 International Circle
Colorado Springs, Colorado 80910

ELECTRICAL COMMITTEE MINUTES

September 11, 2012

MEMBERS PRESENT: Chairman Dennis Hathcock
Vice Chairman Waldo Pendleton
Mr. Mark Mahler
Mr. Daniel McCully
Mr. Ronald Holladay
Mr. Ashton Randall

MEMBERS ABSENTS: None

OTHERS PRESENT: Mr. Henry Yankowski, Regional Building Official
Mr. Dean Wemmer, Chief Electrical Inspector
Todd Welch, Regional Building Official
Ms. Linda Gardner, Executive Administrative Assistant

PROCEEDINGS:

The September 11, 2012 Electrical Committee Meeting was conducted by email.

VARIANCE REQUESTS

1. 10562 Capital Peak, 6186 Wolf Village, 6039 Thurber, 7 Cattle King, 12614 Handles Peak, 5992 San Mateo, 7650 Dellwood, 5685 Revelstoke, 7736 Renegade Hill, 3895 Shining Star, and 9253 Waters Edge - Melvin Denke, Fountain Valley Electrical, requests a variance to Section 210.12, 2011 National Electrical Code, to install regular 15 amp. breakers in place of arc fault breakers.

A motion was made by Ashton Randall to recommend to the Board of Review **APPROVAL** of the variance request, seconded by Daniel McCully; the motion carried unanimously.

Respectfully submitted,

Henry W. Yankowski
Regional Building Official
HWY/llg