

Pikes Peak Regional Building Department

2880 International Circle
Colorado Springs, Colorado 80910

BOARD OF REVIEW AGENDA

July 16, 2014

10:30 a.m.

1. CONSIDERATION OF THE JUNE 18, 2014 BOARD OF REVIEW MINUTES

2. CONSIDERATION OF LICENSING AND MINUTES

a) Building Committee Minutes of July 2, 2014.

b) MEP Committee Minutes of July 9, 2014.

3. DECISION APPEALS

a) 1610, 1630, 1650, and 1690 North Murray Boulevard – Dan Daly, Sigma Metals, requests a variance to Section 1013.3, 2009 International Building Code, to allow a 7” space at the top of a guardrail, where a maximum of 4” is allowed by Code. *The Building Committee denied this variance request due to life safety issues on July 2, 2014.*

4. UNFINISHED BUSINESS

5. NEW BUSINESS

Respectfully submitted,

Henry W. Yankowski
Regional Building Official

HWY/llg