

Pikes Peak Regional Building Department

2880 International Circle
Colorado Springs, Colorado 80910

BOARD OF REVIEW AGENDA

April 15, 2015

10:30 a.m.

1. CONSIDERATION OF THE MARCH 18, 2015 BOARD OF REVIEW MINUTES

2. CONSIDERATION OF LICENSING AND MINUTES

a) Building Committee Minutes of April 1, 2015.

b) MEP Committee Minutes of April 8, 2015.

3. DECISION APPEALS

a) 2011, 2013, 2069 and 2071 Southgate Road – Jeremy Ferranti, Platinum Renovations & Consulting, requests a variance to Section 1009.5, 2009 International Building Code, to allow a stairway landing of 36” x 29”, where 36” x 36” is required. *This Item was DENIED during the March 4, 2015 Building Committee Meeting due to life safety issues, and there are options to correct the landings.*

4. UNFINISHED BUSINESS

5. NEW BUSINESS

Respectfully submitted,

Henry W. Yankowski
Regional Building Official

HWY/llg