

Pikes Peak Regional Building Department

2880 International Circle
Colorado Springs, Colorado 80910

BOARD OF REVIEW AGENDA

April 19, 2017

10:30 a.m.

1. **CONSIDERATION OF THE MARCH 15, 2017 BOARD OF REVIEW MINUTES**

2. **CONSIDERATION OF LICENSING AND MINUTES**

a) Technical Committee Minutes of April 5, 2017.

b) Licensing Committee Minutes of April 12, 2017.

3. **DECISION APPEALS**

a) 834 West Bijou Street, Permit K32970 – Jayme Bailey, JMB Construction, LLC, requests a variance to Section R311.7.2, 2009 International Residential Code, to allow a 5’11” head height above the stairs where a minimum of 6’8” is required. *The Technical Committee DENIED this variance request on March 1, 2017 due to life safety issues.*

4. **UNFINISHED BUSINESS**

5. **NEW BUSINESS**

Respectfully submitted,

Roger N. Lovell
Regional Building Official

RNL/lhg