

2009 IECC Proposed Amendments Plbg/Mech

RBC308.4.9 Section 403.3 Mechanical system piping insulation. Add an exception as follows:

Exception: Mechanical system piping or portions thereof located completely inside the building envelope.

RBC308.4.10 Section 403.4 Circulating hot water systems. Add an exception as follows:

Exception: Circulating hot water systems installed with integral automatic timers.