

EUFER GROUNDING

The 2005 National Electrical Code, adopted by the state of Colorado, effective July 1, 2005, now requires Eufer grounding methods in the foundations of residential and commercial buildings. Exterior grounding rods are no longer acceptable. Refer to Section 250.50, 2005 NEC, for more information. Grounding will be checked at the time of the building footer inspection (BFT). These examples of Eufer grounding installations per the type of foundation are not intended to alter or replace code requirements.

