

## Electrical Permits Required for Hard Wired AC Installations

In addition to the mechanical permit, an electrical permit is required for installation of hard-wired new and replacement air conditioning condensing units, including rooftop units. Installations must comply with Article 440 of the 2002 National Electric Code.

Note: Electrical permits are not required for plug-in air conditioning units or replacement furnaces. New furnace installations are covered under the general permit for new construction.

Effective Oct. 1, 2003