

PIKES PEAK REGIONAL BUILDING DEPARTMENT

Manufactured Housing

TEMPORARY SET UP (piers and anchors)

Pikes Peak Regional Building Department performs electrical inspections for the State of Colorado.

NOTE: Metal piping and ducts are to be bonded per NEC 550.16 (c) (3), #6 or #4 for 200A service.

