

# PIKES PEAK REGIONAL BUILDING DEPARTMENT

## Concrete-Encased Electrode (Eufer)

The 2008 NEC requires a concrete-encased electrode per 250.52(A)(3). These examples of concrete-encased electrode installation, per the type of foundation, are not intended to alter or replace code requirements.

