



P.O. Box 410  
Schofield, WI 54476

---

Phone: 715.359.6171  
[www.greenheck.com](http://www.greenheck.com)

April 28<sup>th</sup>, 2016

Mark Setter  
CFM Company

Subject: Shaft Lobby 2000

Dear Mark:

In regards to the detail that is listed for framing, in our opinion as a manufacturer the detail is acceptable and will not affect the performance of the life safety damper. Local code authority or the authority having jurisdiction will ultimately make the call, but with our experience with life safety dampers and UL tested products this is acceptable.