



Chiartano Engineering Group, LLC
(719) 257-2091
info@chiartanoeg.com

06/11/2025

Pikes Peak Regional Building Department

Re: AAV Engineer Approval Letter

2395 Briargate Blvd, Suite 100 Colorado Springs, CO

Permit #P49129

Plumbing Inspector,

An air admittance valve is acceptable for the relocated lavatory in room 018 and shall be installed per 2021 IPC Section 918 requirements.

If you have any questions, please feel free to contact me at 719-330-6823 or email me at michael@chiartanoeg.com

Thanks,



Michael Chiartano, PE
Colorado License #53302
Chiartano Engineering Group, LLC