

STANDARD BACTERIOLOGICAL WATER TEST

METHOD: SM-9223B

El Paso County Public Health Laboratory

EPA ID# CO00025

1675 West Garden of the Gods Road, Suite 2044, Colorado Springs, CO 80907 • (719) 578-3120

PWSID # C O O

☐ Raw☐ FinishedSample Taken: Date 7/24/17 Time 3:00 Name of Supply _____Address where sample was taken: 6485 CONNAUGHT DR.Sample site location KITCHEN SINK Sampler _____ Chlorine _____ mg/L☐ Community Supply☒ Private☒ Well☐ City☐ Non-Community☐ EHS☐ Surface/Spring☐ CisternResults to RANDY O'LEARY/TICO D+C Phone 719-491-6885Mailing address PO Box 1204City/State/Zip: MONUMENT, CO. 80132Fax (Email) RKKTt 780@aol.comDate 7/24/17 Time 10:35 Rec'd 17/17Date 7/24/17 Time 10:35 Tested XDate 7/25/17 Time 10:45 Comp. _____Tech KSLab Sample # 0749117

Coliform Results Per 100ml

☒ Absence: Absence of coliform bacteria☐ Presence: Presence of coliform bacteria & non-compliance with drinking water standards.. The water supply should be treated & retested.

MPN/100 ml _____

☒ Absence: E. Coli: Escherichia coli bacteria☐ Presence:

MPN/100ml _____

Permit # K62418