

Yee Consulting Engineering, Inc.

11340 Brockton Lane
Peyton, Colorado 80831

Telephone (719) 495-7515
FAX (719) 495-7520

February 22, 1999

D42613

Project: Sakura Commercial and Residential Building
1914 West Uintah Street
Colorado Springs, CO

Re: Stepped wall footing detail

It has been brought to my attention that the concrete stepped wall footing has not been poured per the standard detail shown on Detail E/S-2. This detail indicates the steps shall be 16". The contractor has poured the steps 30" & 36", and also added two (2) #4 rebars running diagonal in the wall along the stepped footings. This modification is acceptable.

If you have any questions regarding these issues please do not hesitate in calling me at (719) 495-7515

Darrell Yee, P.E.
Yee Consulting Engineering, Inc.

