

Architecture
Structural
Geotechnical



Materials Testing
Forensic
Civil/Planning

ROCKY MOUNTAIN GROUP

Job No. 153795

October 25, 2016

Challenger Colorado, LLC
8605 Explorer Drive, Suite 250
Colorado Springs, CO 80920

Re: Footing and Reinforcing Observations
7239 Cedar Brush Ct
Lot 72, Trails at Forest Meadows, Filing No. 3
Colorado Springs, Colorado

Dear Challenger Colorado, LLC:

At your request, Rocky Mountain Group (RMG) has observed the placement of the footing forms and the placement of the reinforcing for the foundation walls and Eufer grounding bar at the address referenced above on October 21 and 25, 2016.

The footing forms and the reinforcing were found to be placed in general compliance with the foundation design by RMG last dated October 21, 2015, Job No. 149408. The Eufer grounding bar was placed according to Section 250.50, 2005 National Electrical Code.

Note, these observations did not include verification of anchor bolts (size, spacing, or embedment depth) or tie-downs. It is our understanding that these components are to be observed by others.

Should you have questions, please do not hesitate to call.

Cordially,

Tony Munger, P.E.
Geotechnical Project Engineer



Southern Office:
Colorado Springs, CO 80918
719.548.0600

Central Office:
Englewood, CO 80112
303.688.9475

Northern Office:
Evans, CO 80620
970.330.1071

Monument: 719.488.2145
Woodland Park: 719.687.6077
Erbil/Kurdistan Iraq: 0750 192 99 44
Ulaanbaatar, Mongolia: 976 99106671